

OFFICE OF THE EXECUTIVE ENGINEER
RURAL WORKS DIVISION, BALASORE.

No. 7959 Date. 25/11/19

To

The Principal
Maharsi Vidya Mandir Patrapada,
Punjibag, Sunhat, Balasore, Pin Code No.756002


Sub:- Issue of Building safety certificate in favour of "Maharsi Vidya Mandir"
Balasore.

Sir,

With reference to the above cited subject, it is to state that, I am enclosing herewith the report of Assistant Executing Engineer, R.W.Sub-Division, Balasore regarding building safety certificate of above mentioned building.

This is for favour of your kind information and necessary action.

Yours faithfully


Executive Engineer,
R.W. Division, Balasore.

22/11/19

OFFICE OF THE ASSISTANT EXECUTIVE ENGINEER,
RURAL WORKS SUB- DIVISION, BALASORE.

NO 167 /Dt. 21.11.19

TO

The Executive Engineer,
R.W.Division, Balasore .

Sub :- Issue of building safty Certificate in favour of "Maharishi
Vidya Mandir" Balasore.

Ref:- Your Memo NO- 7660/WE dt.31.10.2019.

Sir,

With reference to the subject cited above and memo under reference I am to inform you that, I have inspected the above private building on dt.16.10.2019 where the institution is functioning. As per field enquiry and basing on the documents submitted by the principal of the institution, it is observed that the School is situated over plot No-620,620/1321,620/1386,1321/1387/2 of Mouza patrapada under Chandipur P.S. in the District of Balasore . It is to mentioned here that the total area of School premises is A2.02 dec. and all the plots are belonging to gharabadi kizam.

The main building is situated inside the compus of the institution having Plinth Area of 2309.80 sqm in two phases. The building plan have also been approved by BRIT, Balasore since dt. 21.10.2000. It is seen that a two storeyed building have been constructed with R.C.C. roofing over the above mentioned plot . All the walls are made up by brick work and other components like plastering, flooring, doors and windows are in good condition. As such there will be nothing any problem if any eductional institution will function in the said building for safty point of view.

This is for favour of your kind information and necessary action.

Yours faithfully,



Asst. Executive Engineer,
R.W.Sub-Division, Balasore


21/11/19

